

Testing Results of Setting microbial counts from air(2016.6.22)

Testing Area: B.S Animal room , clean Animal room , conventional Animal room .

Testing Time: once three month

Specimen description:-9 cm Sabouraud agar plate Sampling method: Sabouraud plates incubate in the 22°C 5days

Sampling time: 30 minutes

Testing Result: Average of microbila counts from air. < 200 CFU

B.S. Area (A area)

Item	A1	A2	A3	A4	A5	A6	A7	A8
1	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0
Average	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

B.S. Area (B area)

Item	B1	B2	B3	B4	B5	B6	B7	B8
1	0	0	0	0	3	0	0	1
2	3	0	0	0	1	1	0	0
Average	1.50	0.00	0.00	0.00	2.00	0.50	0.00	0.50

B.S. Area (C area)

Item	C1	C2	C3	air shower	Bath
1	0	0	0	0	2
2	0	0	1	1	2
Average	0.00	0.00	0.50	0.50	2.00

B.S. Area

Item	A Path	B Path	C Path	Central Path	A buffer Zone	B buffer Zone	Sterilizaton
1	0	0	0	0	0	1	0
2	0	0	0	0	1	1	0
Average	0.00	0.00	0.00	0.00	0.50	1.00	0.00

Examiner:

Veterinarian:

Chief of Veterinary Services:

Director of Laboratory Animal Centre

唐明珠

獸醫師
英玲

李男陞

實驗室動物中心
中心主任 陳俊銘

Clean Area

Item	Path	Item	R1	R2	R3	R4	108	110-1	110-2
Front 1	0	air inlet 1	0	0	0	0	0	0	1
Front 2	1	air inlet 2	0	0	0	0	0	0	1
Average	0.50	Average	0.00	0.00	0.00	0.00	0.00	0.00	1.00

East Area

Item	Change shoes-1	Change shoes-2	Inside Path	Outside Path	E-Front	E-middle	ER1	ER2	behavior Lab
1	0	3	0	2	2	0	0	0	0
2	0	3	0	0	0	0	0	0	0
Average	0.00	3.00	0.00	1.00	1.00	0.00	0.00	0.00	0.00

East Area

Item	P2-Front	P2-Path	P2-Lab	P2-1	P2-2	P2-buffer zone	Monkeys	Sterilization
1	0	0	0	0	0	0	3	1
2	1	0	0	0	0	0	6	0
Average	0.50	0.00	0.00	0.00	0.00	0.00	4.50	0.50

Quarantine Room

Item	Q1	Q2	Q3	Inside Path	Front
exhaust 1	3	1	0	0	0
exhaust 2	0	0	0	0	0
Average	1.50	0.50	0.00	0.00	0.00

Rabbit Room

Item	R1	R2	Front	Path
air inlet 1	0	0	0	0
air inlet 2	0	0	1	0
Average	0.00	0.00	0.50	0.00

Conventional Room

Item	106	107
air inlet 1	0	0
air inlet 2	0	0
Average	0.00	0.00

圖資動物房

Item	B108-1	B108-2	B120	B112-1	B112-2	Path	Sterilization
air inlet 1	0	12	1	0	0	1	1
air inlet 2	2	6	0	0	0	1	0
Average	1.00	9.00	0.50	0.00	0.00	1.00	0.50

Examiner :

唐明珠

Veterinarian:

獸醫
孫英

Chief of Veterinary Services:

張五子

Director of Laboratory Animal Center:

實驗動物中心
中心主任 陳俊銘